

OFFICE OF THE EXECUTIVE ENGINEER
PUBLIC HEALTH DIVISION KISHANGANJ

Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj

Sample Collected By: -School Staff

District-Kishanganj																
Sl.No	Block	Panchyat	Location	Turb.	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	NO ₃	SO ₄	F	Cond.	T.D.S
1	Kishanganj	Nagar	Oriental Public School Teghariya Kishanganj (Treated Water)	1	7.1	0.3	60	64	18	4	28	B.D.L	10	0.60	146	95
Desirable limit				1NTU	6.5-8.5	0.3 mg/l	200 mg/l	200mg/l	75mg/l	30mg/l	250mg/l	45mg/l	200mg/l	1.0mg/l	...	500 mg/l
permissible Limit in absence of alternate source IS:10500 :2012				5NTU	NR	1.0 mg/l	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	NR	400mg/l	1.5mg/l	μ mhos/cm	2000 mg/l

NR- No Relaxation

B.D.L-Below detection limit.

Rajiv
01/06/19
Lab.Assistant
P.H. Division Kishanganj

SK
01/06/19
Chemist
P.H.Division.Kishanganj

SK
01.06.19
Executive Engineer
P.H. Division Kishanganj